



Product Service

CERTIFICATE

No. Z1 11 03 74851 001

Holder of Certificate: Henan Hanwei Electronics Co., Ltd.No. 169, Xuesong Road
National Hi-Tech Zone
450001 Zhengzhou
PEOPLE'S REPUBLIC OF CHINA**Production Facility(ies):** 74851**Certification Mark:****Product:** Alarm Equipments
Combustible Gas Alarm**Model(s):** KAB**Parameters:**
Rated input voltage: 230VAC
Rated input frequency: 50Hz
Rated input power: 3W
Protection Degree: IPX2D
Target gas: Natural gas (CH4)
Type of apparatus: Type B
Alarm set point: 10% LEL**Tested according to:** EN 50194-1:2009

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.: BJ4000800101**Date,** 2011-03-16

Page 1 of 1

(Yong Zhao)